



# Dallas Fire-Rescue News Release

RELEASE DATE		TIME	PUBLIC INFORMATION CONTACTS		
January 8, 2008		1000 HR	Sherrie Lopez, PIO Paul Lara, PIO		
ADDRESS		PHONE	CELL	E-MAIL	
3501 McKinney / Lemmon Ave		214-670-7949	469-323-5880 469-323-5881	Sherrie. Lopez@ dallascityhall.com	
STRUCTURAL LOSS	CONTENTS LOSS	TOTAL LOSS	OCCUPANCY TYPE	UNITS DAMAGED	
1,020,000 M	1,014,000 M	2,034,000 M	Strip Shopping Center	1	
CIVILIANS FATALITES	CIVILIAN INJURIES	FIREFIGHTER INJURIES			
0	0	0	0	0	
TOTAL RESCUE AMBULANCES	TIME TO CONTROL INCIDENT	FIREFIGHTERS ON SCENE	FIRE COMPANIES	ADDITIONAL FIRE COMPANY	
3	APPROX. 1Hr	75	14	1 – HAZMAT CREW	
EXTRA ALARMS		INCIDENT CAUSE			
1 <sup>st</sup> @ 1449, 2 <sup>nd</sup> @ 1459, 3 <sup>rd</sup> @1523 Tapped Out at 1612		ELECTRICAL SHORT IN CEILING ABOVE A/C – HEATING DUCTS			
INCIDENT DESCRIPTION					
<p><b>3-ALARM FIRE CONSUMES BIBBENTUCKERS DRY CLEANING</b></p> <p>Firefighters arrived at Bibbentuckers and reported out with heavy smoke rolling from the top of the structure. Thirty-one employees had already exited to safety. Second and third alarm responses followed soon after. Two aerial ladder-pipes were set and ready to pour water on the roof if necessary; however ground crews, aided by a firewall aggressively battled the interior blaze keeping the fire confined to the business. The other adjacent businesses suffered heavy to moderate smoke damage. No injuries were reported.</p>					

